



Tri-City / William Lloyd Analytical Laboratory

9300 Poplar Bridge Road • Bloomington, MN 55437 • (952) 563-4904

Sample Results Report

Inspection Services
7841 Wayzata Blvd Ste 100
St. Louis Park, MN 55416

Report Date:
1/1/2022 13:00

Received By: Bree Landherr

Sample Condition Upon Receipt:

Received Date / Time: 1-1-2022 10:43

Acceptable Temperature 4.9 °C

On ice

Sample ID: 2206205-01

1234 Main Street, Andover, MN 55304 (exterior hosebib) Sample

Collector: Tony Stark aka Ironman

Collection Date/Time: 1/1/2022 8:40:00AM

Analyte	Result	Units	MCL*		Date Analyzed	Analyst Initials	Method
Arsenic	<2.00	ug/L	10	PASS	1/1/2022 12:51	BL	EPA 200.5 Rev. 4.2
Nitrate as N	<0.0500	mg/L	10	PASS	1/1/2022 11:23	BL	EPA 353.2 Rev. 2.0
P/A total coliform	Absent	MPN/100 mL	Absent	PASS	1/1/2022 15:00	BL	SM 9223 B (Colilert-18® P/A)

*MCL (maximum contaminant level) set by the EPA

PASS - The analyte(s) reported, for the sample(s) listed above, meet standards set by the Minnesota Department of Health and U. S. Environmental Protection Agency for safe drinking water.

Approved By:

Bree Landherr

Laboratory Analyst

Laboratory Identification Number: 027-053-355

The results in this report apply to the above listed sample(s). All routine quality assurance procedures were followed, unless otherwise noted. This analytical report must be reported in its entirety. All methods are certified by the Minnesota Department of Health, unless otherwise noted. The test report shall not be reproduced except in full, without written approval of the laboratory.

* - The lab does not hold a Minnesota Department of Health accreditation for this parameter.